

SSO Notification List												
August 2010												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	8/1/2010	2902 Glenmore Ave	21214	Roots & Grease	Herring Run	3:30	11:15 AM - 2:45 PM	Gray Colored Water	630	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111888
2	8/3/2010	2418 Wilgrey Court	21230	Rags & Grease	Inner Harbor	9:30	11:10 AM - 8:40 PM	Sewer Water, Feces, Grease, Paper Debris	8,550	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111960
3	8/5/2010	3118 Brighton Street	21218	Rags, Grease & Debris	Gwynns Falls	7:30	3:15 PM - 10:45 PM	Sewer Water, Grease, Paper Debris	2,250	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112046
4	8/4/2010	100 Woodlawn Road	21210	Rags & Roots	Jones Falls	4:35	1:25 PM - 6:00 PM	Rags & Roots	275	Relieved H/C Choke with Electric Machine	Turned lined over to be CCTV'ed	112008
5	8/5/2010	3900 Belair Road	21213	Pipe Break	Herring Run	57:00	8-3-10 10:00 AM to 7:00 PM 8-5-10	Gray Water	23,940	Used By Pass Pump and Sand Bags	Repairs will be made	111959
6	8/7/2010	4100 Belair Road	21213	Pipe Break	Herring Run	3:00	8:30 AM - 11:30 AM	Sewer Water	18,000	Used By Pass Pump and Sand Bags	Repaired line to re-rout Sewage back to M/L	111959
7	8/9/2010	1015 N Ellamont Street	21216	Rags, Roots & Grease	Gwynns Falls	2:21	12:12 PM - 2:33 PM	Heavy Gray Water	423	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112107
8	8/11/2010	1000 Ellicott Drive Way	21216	Rags, Roots & Grease	Gwynns Falls	2:14	11:35 AM - 1:09 PM	Heavy Gray Water	268	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112223
9	8/11/2010	3807 Greenmount Ave	21218	Rags, Grease & Debris	Jones Falls	0:50	7:45 PM - 8:35 PM	Sewer Water	250	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112225
10	8/12/2010	1015 N Ellamont Street	21216	Rags, Grease & Debris	Gwynns Falls	2:20	5:50 PM - 8:10 PM	Sewer Water	1,400	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112268
11	8/13/2010	219 Collins Ave	21229	Rags	Gwynns Falls	2:30	4:00 PM - 6:30 PM	Gray Water	750	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112313
12	8/13/2010	121 Woodlawn Road	21210	Roots	Jones Falls	1:00	11:30 AM - 12:30 PM	Gray Water	300	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112287
13	8/14/2010	1338 Sherwood Road	21227	Rags, Roots & Grease	Herring Run	2:00	9:10 AM - 11:10 AM	Heavy Gray Water	600	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112330
14	8/16/2010	3815 Stokes Drive	21229	Rags, Roots & Grease	Gwynns Falls	1:00	10:18 AM - 11:18 AM	Heavy Gray Water	180	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112376
15	8/19/2010	2300 Chilham Road	21209	Pipe Break	Jones Falls	4:34	1:41 PM - 6:15 PM	Heavy Gray Water	1,644	Temporary Repaired with 10 inch Pipe	Construction to make Permanent Repair	112527
16	8/20/2010	1815 Bolton Street	21217	Rags, Grease & Debris	Gwynns Falls	1:30	10:00 Am - 11:30 AM	Sewer Water	180	Relieved Choke at House Connection	Turned lined over to be CCTV'ed	112551
17	8/23/2010	857 Glen Allen Drive	21229	Rags & Roots	Gwynns Falls	3:19	7:59 AM - 11:18 AM	Gray Colored Water	Evidence of Overflow	Relieved H/C Choke with Pressure Truck	Turned lined over to be CCTV'ed	112641
18	8/24/2010	2400 W Northern Parkway	21215	Rags & Roots	Jones Falls	2:00	8:00 AM - 10:00 AM	Heavy Gray Water	1,200	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112706
19	8/26/2010	4200 W Franklintown Road	21229	Pipe Break	Gwynns Falls	27:00	08-26-10 8:00 AM to 11:00 AM 08-27-10	Heavy Gray Water	1,620	Repaired M/L Break with PVC Pipe	No preventative action required - Repair Completed	112810
20	8/28/2010	6300 O'Donnell Street	21224	Rags & Grease	North West Harbor	4:00	2:00 PM - 6:00 PM	Gray Colored Water	240	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112874
21	8/29/2010	420 Hutchins Ave	21212	Rags, Grease & Sand	Herring Run	2:05	7:45 PM - 9:50 PM	Gray Water	625	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112897
22	8/30/2010	2400 W Northern Parkway	21215	Rags & Roots	Jones Falls	4:00	10:00 AM - 2:00 PM	Heavy Gray Water	1,200	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112919
23	8/30/2010	907 Nottingham Road	21229	Rags, Roots & Grease	Gwynns Falls	2:11	10:49 AM - 1:00 PM	Heavy Gray Water	655	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112917
24	8/30/2010	2509 Talbot Road	21216	Rags & Grease	Jones Falls	0:51	4:49 PM - 5:40 PM	Gray Water	102	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	112928
								TOTAL	65,282			